

THE ANACONDA COPPER COMPANY
New Mexico Operations

The Anaconda Copper Company
P.O. Box 638
Grants, New Mexico 87020

MICROBIOLOGICAL WATER REPORT

Sample Identification

Water System Supply Name Jackpile P-10
Date Received November 24, 1980
Time Received 9:50 am
WSS Code Number 973-32

Collection Information

Date Collected November 24, 1980
Time Collected 8:00 am
Collection Point Jackpile P-10
Collected By W. Lewis

Type of System (Check one)

☒ Public Non Community ☐ Public Community
☐ Private Well ☐ Swimming Pool

Reason For Sampling (Check one)

☒ Routine Sample ☐ Special Sample
☐ Check Sample ☐ Monitoring Sample
Other _____

Testing Required (Check one)

☒ Potability - Sample required for the Safe Drinking Water Act ☐ Fecal-Coliform
Other _____

PUBLIC SYSTEM ONLY

☒ This sample complies with the Safe Drinking Water Act
☐ This sample does not comply with the Safe Drinking Water Act. (Notify local environmentalist.)

Analyst David C. Lyba

Date Reported Dec. 2, 1980

Laboratory Test Results

		Type of Test
Total	<u>21</u> per 100ml	MF
Confirmed	_____ per 100ml	MPN
Total	_____ per 100ml	MPN
Fecal	_____ per 100ml	MF
Fecal	_____ per 100ml	MPN
Non Coliforms	_____ per 100ml	MF
Other	_____	
Comment	_____	

CONFIDENTIAL

POL-EPA01-0005505

THE ANACONDA COPPER COMPANY
New Mexico Operations

The Anaconda Copper Company
P.O. Box 638
Grants, New Mexico 87020

MICROBIOLOGICAL WATER REPORT

Sample Identification

Water System Supply Name Jackpile Well #4
Date Received November 24, 1980
Time Received 9:50 am
WSS Code Number 733-32

Collection Information

Date Collected November 24, 1980
Time Collected 7:40 am
Collection Point Jackpile Well #4
Collected By W. Lewis

Type of System (Check one)

☐ Public Non Community ☒ Public Community
☐ Private Well ☐ Swimming Pool

Reason For Sampling (Check one)

☒ Routine Sample ☐ Special Sample
☐ Check Sample ☐ Monitoring Sample
Other _____

Testing Required (Check one)

☒ Potability - Sample required ☐ Fecal-Coliform
for the Safe Drinking Water Act
Other _____

PUBLIC SYSTEM ONLY

☒ This sample complies with the Safe Drinking Water Act
☐ This sample does not comply with the Safe Drinking Water
Act. (Notify local environmentalist.)

Analyst Levi C. Lybba

CONFIDENTIAL

orted

Dec. 2, 1980

Laboratory Test Results

Type of
Test

Total <1 per 100ml MF
Confirmed _____ per 100ml MPN
Total _____ per 100ml MPN
Fecal _____ per 100ml MF
Fecal _____ per 100ml MPN
Non Coliforms _____ per 100ml MF
Other _____

Comment POL-EPA01-0005506

THE ANACONDA COMPANY
WATER ANALYSIS

DESCRIPTION	DATE	Cl ppm	SO ₄ ppm	NO ₃ ppm	Na ppm	Cond umhos	pH	U-Nat pCi/l	Ra-226 pCi/l	Th-230 pCi/l
Jackpile P-10 Well	11-07-80	25	640	1	386	1900	8.6	11.00	0.64	1.75
Jackpile New Shop Well	11-07-80	28	672	1	397	2000	8.6	1.80	2.13	1.66

WATER PUMPED

(Fourth Quarter, 1980)

<u>LOCATION</u>	<u>GALLONS</u>
P-10 Well	716,300
New Shop Well	550,650
P-10 Mine	7,276,400